

# Tillamook Fire District

*Proudly Serving the Citizens of Central Tillamook County*

## Chapter 1 - Scope & Administration

- 105 - Permits - Required
- 105 - Permits - Open Burning / available to residential/Ag properties only
- 106 - Compliance No Violation Noted
- 107 - City of Tillamook Business Registration

## Chapter 3 - General Requirements

- 315 - General Storage - Orderly & Separated
- 315 - General Storage - Ceiling Clearance
- 315 - General Storage - Egress
- 315 - General Storage - Equipment Rooms

## Chapter 5 - Fire Service Features
































- 503 - Fire Access Roads – Obstruction / clear width and height
- 505 - Premises Identification – Address / 4" lettering on contrasting background
- 506 - Key Boxes – Required / for all sprinklered or monitored facilities
- 506 - Key Boxes - Gate Locks
- 506 - Key Boxes - Maintenance
- 507 - Fire Protection Water Supplies - Hydrant Obstruction
- 507 - Fire Protection Water Supplies - Hydrant Clear Space / 3' from anything
- 507 - Fire Protection Water Supplies - Hydrant Protection

## Chapter 6 - Building Services & Systems

- 605 - Electrical Equipment - Illumination
- 605 - Electrical Equipment - Clearance from Panel / 30" or width of panel if more
- 605 - Electrical Equipment - Clearly Marked Door
- 605 - Electrical Equipment - Multiplug Adapters
- 605 - Electrical Equipment - Power Tap Design
- 605 - Electrical Equipment - Supply
- 605 - Electrical Equipment - Installation
- 605 - Extension Cords - Not Permanent / 90 days maximum
- 605 - Extension Cords - Power Supply
- 605 - Extension Cords – Ampacity / ensure it can support imposed loads





















# Tillamook Fire District

*Proudly Serving the Citizens of Central Tillamook County*

	605 - Extension Cords – Maintenance / wiring intact, not through doors or walls
	605 - Extension Cords – Grounding / ground plug intact
	605 - Electrical Equipment - Unapproved Conditions / cover plates intact
	605 - Electrical Equipment - Electrical Motors
	605 - Electrical Equipment - Temporary Wiring / 90 days maximum
	605 - Electrical Equipment - Portable Heaters / plugged into outlet only
	607 - Elevator - Emergency Recall
	607 - Elevator - Emergency Signs
	607 - Elevator - Key Location
	609 - Commercial Kitchen Hoods – Required / Type I and II
	609 - Commercial Kitchen Hoods - Exhaust Fan
	609 - Commercial Kitchen Hoods – Inspection / semi-annually
	<b>Chapter 7 - Fire Resistance Rated Construction</b>
	703 - Fire Resistance Rated Construction – Maintenance / walls and ceilings
	703 - Fire Resistance Rated Construction - Door Devices
	703 - Fire Resistance Rated Construction - Door Operation / make sure they close
	703 - Fire Resistance Rated Construction - Acoustical Ceiling
	<b>Chapter 8 - Interior Finishes &amp; Decorations</b>
	807 - Decorative Materials - Artwork Exceeds 20%
	807 - Decorative Materials - Corridors & Lobbies
	807 - Decorative Materials - Requirements A,E,I,R1,R2 Occupancies
	<b>Chapter 9 - Fire Protection Systems</b>
	901 - General - Annual Sprinkler Maintenance / wet and dry systems
	906 - Fire Extinguisher – Required
	906 - Fire Extinguisher - Annual Maintenance / 3 <sup>rd</sup> party vendors
	906 - Fire Extinguisher - Conspicuous Location / visible and/or marked
	906 - Fire Extinguisher - Unobstructed View /
	906 - Fire Extinguisher Installation Height / less than 5’ more than 4”
	906 - Fire Extinguisher - Minimum Rating - 2A10BC / for low hazard
	912 - Fire Department Connections - Existing Buildings
	912 - Fire Department Connection – Access / don’t have it blocked

# Tillamook Fire District

*Proudly Serving the Citizens of Central Tillamook County*

	912 - Fire Department Connection - Clear Space / 3' minimum, cut the brush
	912 - Fire Department Connection – Protection / bollards in place
	912 - Fire Department Connection - Testing & Maintenance
	<b>Chapter 10 - Means of Egress</b>
	1004 - Occupant Load - Posted
	1005 - Means of Egress Sizing - Width Encroachment
	1006 - Means of Egress Illumination - Required
	1006 - Means of Egress - Brightness
	1006 - Means of Egress - Power Source / hardwired w/ battery backup
	1008 - Doors - Clearly Distinguished
	1008 - Doors - Minimum Width
	1008 - Doors - Minimum Height
	1008 - Doors - Travel/Swing / assembly occupancies outswing
	1008 - Doors - Opening Force / less than 15 pounds to open
	1008 - Doors - Operation
	1008 - Doors - Hardware
	1008 - Doors - Panic Hardware / push bars for assembly occupancies
	1011 - Exit Signs – Required
	1011 - Exit Signs – Illumination / hardwired w/ battery backup
	1030 - Maintenance of the Means of Egress - Obstructions